

NEWCOMER ASSOCIATES

architecture + engineering



ARCHITECT: Newcomer Associates
1105 Sheller Avenue
Chambersburg, PA 17201
Phone: 717-263-0101; Fax: 717-263-7380

PROJECT: King Street Church (Project No. 1526)
Chambersburg, Pennsylvania

DATE: March 24, 2016

ADDENDUM #2
(Clarifications and Revisions)

SPECIFICATIONS:

2.01 Section 00 11 16 Invitation to Bid

A. REVISE Bid Due Date April 1, 2016 @ 12:00 Noon

2.02 Section 06 20 00 Finish Carpentry

A. ADD Paragraph 2.3I

2.3I All enclosed adjustable closet shelving to be white melamine board with finished ends and edges.

2.03 Section 06 41 00 Architectural Casework

A. DELETE Paragraph 2.3D and 2.3F

D. Drawer Slides:

1. Knappe and Vogt No. 8500 for drawers.
 - a. 150 lb load minimum.
 - b. Full extension

F Door and Drawer Locks: K20 Kenstan lock with slotted strike plate

2.04 Section 06 61 16 Solid Surface Fabrications

A. REVISE Paragraph 2.1.A.1

A. Countertops

1. Corian Group C. Color chosen by Architect.

Jennifer A. Greenlee, AIA

T. Kim Jackson, P.E.

Matt J. Runyon, P.E., C.B.O.

DRAWINGS:

2.05 Sheet A001 Demo and Roof Plans (Revision #1 dated 03/16/16, Drawing will not be reissued)

- A. REVISE Demolition Schedule Type D24
D24 - Demolish existing perimeter gypsum board, insulation and furring if present to expose existing CMU wall. Where plaster is adhered directly to CMU wall demolition is unnecessary. New furring and finish can be applied over plaster.

2.06 Sheet A401 Enlarged Floor Plan (Revision #1 dated 03/16/16, Drawing will not be reissued)

- A. REVISE Wall Tag
Wall tag PB3 located in Resource Room 122 at elevation A701M should be PB5

Addendum #2 has been uploaded to the FTP site into the "PDF (Current Set)" folder and "Addendum #2" folder for your immediate use and distribution. If you have any questions, please contact me.

END OF ADDENDUM #2