

Barry Best

From: Barry Best [babsurv@comcast.net]
Sent: Wednesday, June 08, 2016 12:50 PM
To: American Legion Post 517
Subject: FW: Mercersburg American Legion

From: Barry Best [mailto:babsurv@comcast.net]
Sent: Wednesday, June 08, 2016 12:17 PM
To: 'Bill Sanders'
Cc: 'Travis - P&W Excavating'; 'aaapaving@embarqmail.com'; 'EricDeardorff@Fayettevillecontractors.com'
Subject: Mercersburg American Legion

ADDENDUM No. 1:

1. The graphic scale on sheets S-1, S-2, S-3, S-4 should be changed to 1" = 20'. Disregard the graphic scale on sheets S-5 and S-6.
2. The bid date has been extended to 16 June 2016 at 6:00 PM, prevailing time.

Barry A. Best
Barry A. Best Surveying
402 Bear Valley Road
Fort Loudon, PA 17224
717-369-2249
Cell: 717-360-5676
babsurv@comcast.net

Barry Best

From: Barry Best [babsurv@comcast.net]
Sent: Wednesday, June 08, 2016 1:14 PM
To: American Legion Post 517
Cc: 'aaapaving@embarqmail.com'; 'EricDeardorff@Fayettevillecontractors.com'; 'Travis - P&W Excavating'
Subject: FW: Parking Lot Improvements

From: Barry Best [mailto:babsurv@comcast.net]
Sent: Wednesday, June 08, 2016 1:11 PM
To: American Legion Post 517
Cc: 'Travis - P&W Excavating'; 'EricDeardorff@Fayettevillecontractors.com'; 'aaapaving@embarqmail.com'
Subject: Parking Lot Improvements

Addendum No. 2

1. Parking Lot Improvements should be completed between 1 August 2016 and 20 August 2016.
If necessary, the Post could close during that time period.

Barry A. Best
Barry A. Best Surveying
402 Bear Valley Road
Fort Loudon, PA 17224
717-369-2249
Cell: 717-360-5676
babsurv@comcast.net

Barry A. Best, Surveying

402 BEAR VALLEY ROAD
FORT LOUDON, PA 17224
PHONE: 717-369-5699
CELL: 717-360-5676
email: babsurv@comcast.net

9 June 2016

Mercersburg American Legion Post 517
100 Keefer Drive
Mercersburg, PA 17236

**Re: Parking Lot Improvements
Mercersburg American Legion Post 517**

ADDENDUM NO. 3

Sheets S-3 and S-4:

1. Changed poured wall and custom grate at Existing inlet to Two (2) Standard inlet boxes with Type M Top and Grate.
2. Added blacktop apron to Inlets I-3.

Sheet S-5

1. Removed wall details and custom grate. Inlets I-3 to have Type M Top With Grate. Inlet boxes can either be precast or poured in place.

Please call if you have any questions.

Sincerely,

Barry A. Best