

ADDENDUM

Project: Wolf Trap Meetinghouse Oakton VA Stake

Project No.: 500900715010601

Addendum No.: 3

Project Address: 1632 Crowell Road, Vienna VA 22182

Date: 05 December 2018

Owner: Corporation of the Presiding Bishop of The Church of Jesus Christ of Latter-day Saints, a Utah corporation sole

From (Architect): L2M Architects

Instructions to Prospective Bidders:

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents and/or prior Addenda as noted below. All conditions, requirements, materials and workmanship are to be as described in the Contract Documents unless specifically stated otherwise. This Addendum consists of 1 page and no attachments.

1. Changes to prior Addenda:
 - a. N/A
2. Changes to Bidding Requirements:
 - a. N/A
3. Changes to Conditions of the Contract:
 - a. N/A
4. Changes to Specifications:
 - a. Section 04 2113 Part 2, 2.1 b.2.c shall be revised to Redland Brick; priced \$650 / 1000, color shall be selected by Owner at later date. Grout shall be as indicated in specifications.
5. Changes to Drawings:
 - a. N/A
6. Clarifications:
 - a. Reference Civil sheet 11 of 66 Geometry Plan regarding are of proposed drainfield (active). Area of active drainfield shall be 7,200 s.f., capacity shall be 682 gallons, tank shall be 3,000 gallons, sanitary lateral from Meetinghouse facility to tank shall be 6" diameter.

End of Addendum